


FLOW HYDRANTS
19 PSI PITOT PRESSURE
2 1/2" DIA. OUTLET
730 GPM FLOW
1.0 NOZZLE VOID COEFF.
730 GPM CORR. FLOW
8" DIA. MAIN SIZE

RESIDUAL HYDRANTS
51 PSI STATIC PRESSURE
42 PSI RESID. PRESSURE
9 LOSS PSI (51-42)
31 LOSS @ 20 PSI
1421 GPM CALC. FLOW
@ 20 PSI
8" DIA. MAIN SIZE



Analyst	Cochran, Stephenson & Dorkenweil, Incorporated
10000 The Warehouse of Camden Yards 333 East Camden Street Baltimore, Maryland 21201 Phone: 410-538-2263 Fax: 410-752-2263	
Mechanical/Electrical Engineer	Gipe Associates, Inc.
10000 Sentry Center I, Suite 102 Baltimore, Maryland 21206 Phone: 410-532-2490 Fax: 410-532-2488	
SEA/Structural Engineer	Orill Engineering, Inc.
10000 81 East Lombard Street, Suite 505 Thousand, Maryland 20683 Phone: 410-252-2271 Fax: 410-596-0071	

[illegible]